

FIREKILL™ Front To Back

Approvals / Acceptance criteria	CEN/BS	CEN/BS	FM	FM	FM	CEN	IMO	CEN	IMO	CEN/VdS	IMO	CEN/VdS	CEN		
Nozzle type	OH-DR1	OH-DR1	OH-VSO	OH-DC1	OH-DC2	OH-VSO	OH-L2	OH-SW	OH-SWC	OH-UPR	OH-PX1	OH-PX2	Atrium		
Equivalent Hazard Group (CEN)	LH	LH	OH1	Data	Data	OH1	OH1	OH1	OH1	OH2	OH3	OH3	OH1		
Max room height	3,5 m	3,5 m	5,0 m	5	1	6 m	5 m	3 m	2,5 m	3 m	2,5 m	4 m	Unlimited		
Max volume / Area	50 m ²	64 m ²	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited	Unlimited		
Classroom base			V			V	V	V	V						
Hall and dining			V			V	V	V	V						
Learning resources			V			V	V	V	V						
Medical therapy/support			V			V	V	V	V						
Corridors / Stair ways			V			V	V	V	V						
Plant											V	V			
Staff and admin			V			V	V	V	V						
Offices			V			V	V	V	V						
Storage											V	V			
Hotel room			V			V	V	V	V						
Restaurants			V			V	V	V	V						
Atriums			V			V	V	V	V						
Void										V					
False Ceilings										V					
Parking garage										V					
Shops											V	V			
Technology areas											V	V			
Hospital rooms			V			V	V	V	V						
Laboratory			V			V	V	V	V						
Heritage building			V			V	V	V	V						
Attic			V			V	V	V	V						
Residential		V	V			V	V	V	V						
Domestic	V		V			V	V	V	V						
Museums			V			V	V	V	V						
Libraries			V			V	V	V	V						
Atrium														V	
Data center				V											
Data center false floor/ceiling					V										

NOTE: DIOM Shall be consulted for exceptions and restrictions on the various nozzles