



CERTIFICATE OF FIRE APPROVAL


This is to certify that

The product detailed below will be accepted for compliance with the applicable Lloyd's Register Rules and Regulations and with the International Convention for the Safety of Life at Sea, (SOLAS), 1974, as amended, for use on ships and offshore installations classed with Lloyd's Register, and for use on ships and offshore installations when authorised by contracting governments to issue the relevant certificates, licences, permits etc.

| | |
|---------------------------|--|
| Manufacturer | VID Fire-Kill ApS |
| Address | Svalbardvej 13 DK-5700 Svendborg Denmark |
| Type | FIXED LOCAL APPLICATION FIRE-FIGHTING SYSTEM |
| Description | Fixed Local Application Fire Extinguishing System – Type: “Skagerrak” Nozzles |
| Specified Standard | IMO MSC.1/Circ. 1387 superseding MSC/Circ. 913 (and superseding MSC.1/Circ.1276) |

The attached Design Appraisal Document forms part of this certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached Design Appraisal Document are complied with and the equipment remains satisfactory in service.

| | | | |
|-----------------|----------------|-------------|---|
| Date of issue | 7 June 2017 | Expiry date | 10 October 2021 |
| Certificate No. | SAS F170002/M1 | Signed |  |
| Sheet No | 1 of 4 | Name | S. Abraham Surveyor to Lloyd's Register EMEA A Member of the Lloyd's Register Group |

Note:

This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Lloyd's Register of any modification or changes to the equipment in order to obtain a valid Certificate.

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



| |
|-----------------------------------|
| Page 2 of 4 |
| Document number SAS F170002/M1 |
| Issue number 1 |

DESIGN APPRAISAL DOCUMENT

| | |
|---------------------|---|
| Date 7 June 2017 | Quote this reference on all future communications SOUTSO/SFS/TA/FF/SA/WP26693236 |
|---------------------|---|

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F170002/M1

This Design Appraisal Document forms part of the Certificate.

APPROVAL DOCUMENTATION

DFL (Danish Fire Laboratories/Svendborg Denmark) Test Reports: 100623-43, dated 15 September 2010 and 110414-2, dated 24 August 2011.

CONDITIONS OF CERTIFICATION

1. The system has been designed in accordance with IMO MSC/Circ. 1387, Annex, "Principle Requirements for the System"
2. For use in Machinery Spaces of Category A for the protection of local hazards. The capacity and arrangement of the spray nozzles is to be denoted in the following;
 - Table 2-1 for Passenger Ships, Cargo Ships, Yachts, High Speed Craft and Tankers **OR;**
 - When the system is provided onboard LR Classed Inland Waterways Passenger ships, the capacity and arrangement of the nozzles shall be specially considered in the design stages in all cases
3. Arrangement drawings and calculations are to be submitted for acceptance in each case where it is proposed to install this system. Control panel schematics are also to be submitted for acceptance in each case where it is proposed to be identified with their location in relation to the protected space(s) indicated
4. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype
5. See GENERAL NOTES

Table 2-1 Recommended Nozzle Arrangements for Passenger Ships, Cargo Ships, Yachts, High Speed Craft and Tankers

| Nozzle Designation | Location | Max. Distance from Hazard | Min. Distin. Distance from Hazard | Spacing | Lateral Distance from Hazard ⁽¹⁾ | Minimum Water Pressure |
|--------------------|----------|---------------------------|-----------------------------------|-----------|---|------------------------|
| | | M | M | M | M | Bar |
| Skagerrak | Ceiling | 11.0 | 0.75 | 1.5 x 1.5 | 0.375 | 12.5 |

⁽¹⁾ The outer nozzles of grid must be located at least a quarter of the maximum nozzle spacing outside of the protected area.

GENERAL NOTES

1. The type approval is restricted to the arrangement and approval of the nozzles only, approval of ancillary components is to be carried out at the design stage



| |
|-----------------------------------|
| Page 3 of 4 |
| Document number SAS F170002/M1 |
| Issue number 1 |

DESIGN APPRAISAL DOCUMENT

| | |
|---------------------|---|
| Date 7 June 2017 | Quote this reference on all future communications SOUTSO/SFS/TA/FF/SA/WP26693236 |
|---------------------|---|

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F170002/M1

2. For installations which may be protected using individual nozzles or a single row of nozzles, the protected area (width and length) is to be in accordance with MSC.1/Circ.1387 for a 3 x 3 nozzle grid (3.4.2.1 & Figures 3.4.2.5 & 3.4.2.6)
3. The minimum CONSTANT nozzle pressure being 12.5 bar.
4. The as tested nozzle is made in NiSn plated naval brass. Each individual water spray nozzle shall be fitted with a mesh strainer (mesh size No. 16, 1200µm). The nozzle characteristics are delineated in Table 4-1:

Table 4-1 - Nozzle Characteristics

| Nozzle designation | K-factor l/min*bar ^{1/2} | Flow at 12.5 bar l/min |
|--------------------|--------------------------------------|---------------------------|
| Skagerrak | 5.6 | 19.80 |

5. Piping and water tank material shall be made of stainless steel having minimum grade of AISI 304L
6. To ensure that the system is capable of 20 minutes operation, in all installations the system is to incorporate a sea water inlet via remotely operated valve, allowing for either an automatic or a manual change-over connection to sea water supply upon loss of fresh water unless alternative arrangements are agreed at the design stage by the plan approval authority. These connections are to be located in the same compartment as the pump unit and in a readily accessible position
7. The system main pump unit, water tank and sea connection shall not be situated in any area required to be protected by the system
8. The pump unit shall have on the pressure side a mess strainer (mesh size No. 50, 300µm)
9. Activation of any water distribution valve (e.g. section valve) should give a visual and audible alarm in the engine control room and the navigating bridge or continuously manned central control station. Audible alarms may use a single tone
10. The number of spare watermist nozzles and parts for the system being provided are to be indicated in the manufacturer's design, installation, operation and maintenance manual
11. The use of subject system in conjunction with or as part of a water based main fire extinguishing system (MSC/Circ. 1165, as amended by MSC/1269) is acceptable and will be specially considered at the design stage provided the local protection system is capable of being isolated from the main system
12. Appropriate operational measures or interlocks should be provided if the engine room is fitted with a fixed high expansion foam or aerosol fire-fighting system, to prevent the local application system from interfering with the effectiveness of these systems
13. Construction details and constituent component of the system as well as calculations are to be submitted for acceptance in each case where it is proposed to install this system. Control panel schematics and if applicable also details of any PLC (Programmable Logic Controller) are to be submitted. All principle components of the system are to be identified with their location in relation to the protected space(s) indicated. The control system is to be surveyed at the manufacturer's works prior to installation on board



| | |
|-----------------|----------------|
| Page | 4 of 4 |
| Document number | SAS F170002/M1 |
| Issue number | 1 |

DESIGN APPRAISAL DOCUMENT

| | |
|---------------------|---|
| Date 7 June 2017 | Quote this reference on all future communications SOUTSO/SFS/TA/FF/SA/WP26693236 |
|---------------------|---|

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F170002/M1

14. The electrical components of the pressure source for the system should have a minimum rating of IPX4 if located in the protected space. Where, X means the characteristic numeral used to mark the degree of protection against access to hazardous parts and ingress of solid foreign objects, which could be 1 to 6
15. Any fire detection and alarm system installed in conjunction with this system is outside of the scope of this Fire Approval Certificate and must be separately approved by Lloyd's Register.
16. Nozzles are to be installed in the vertically downwards position
17. Valves and other piping system components having working pressures exceeding 7 bar, and all pumps and any independent power units are to be constructed under survey. Additionally, the system pipe work including; flexible hoses and pipes are to be LR approved, in accordance with Lloyd's Register Rules, Part 5
18. In the case of Periodically Unattended machinery Spaces, the local application fire fighting system shall have both automatic and manual release capabilities in accordance with revised SOLAS 74 Chapter II-2 Regulation 10.5.6.2. The automatic activation arrangements are in each case to be approved by Lloyd's Register at the design stage
19. On completion of the installation final acceptance of the system is dependent on satisfactory survey and testing in accordance with the manufacturer's Design, Installation, Operation and Maintenance Instructions which being submitted in each case where the system is intended being installed

PLACE OF PRODUCTION

VID Fire-Kill ApS
Svalbardvej 13
DK-5700 Svendborg
Denmark



Saji Abraham
Senior Specialist
Statutory Fire & Safety
Southampton Technical Support Office, Marine & Offshore
Lloyd's Register EMEA

Supplementary Type Approval Terms and Conditions

This certificate and Design Appraisal Document relates to type approval, it certifies that the prototype(s) of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein, it does not mean or imply approval for any other use, nor approval of any products designed or manufactured otherwise than in strict conformity with the said prototype(s).