



Certificate of Compliance

This certificate is issued for the following:

System Designation:	Model K6 Fine Water Spray System
System Type:	Water mist system for the protection of machinery and combustion or steam turbines in enclosures up to 162,801 ft ³ (4610 m ³) and 39.4 ft (12.0 m) in height
Design, Installation, Operation, and Maintenance Manual:	The water mist system is only Approved when installed in accordance with the VID Fire-Kill Model K6 Fine Water Spray System Design, Installation and Maintenance Manual, Doc No 110629-01-02, v.2, dated 15-Aug-2011, and in accordance with FM Global Property Loss Prevention Datasheets.

Prepared for:

VID FIRE-KILL
SVALBARDVEJ 13
DK-5700 SVENDBORG
DENMARK

Manufactured at:

VID FIRE-KILL
SVALBARDVEJ 13
DK-5700 SVENDBORG
DENMARK

FM Approvals Class: 5560

Approval Identification: 3040609 Approval Granted: September 9, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne".

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group